SPECIFICATIONS

HYDROGEN MASER

STABILITY

Allan deviation (measured in 1Hz bandwidth):

Averaging Time	Stability
1s	Less than or Equal to 2.0E-13
10s	Less than or Equal to 5.0E-14
100s	Less than or Equal to 1.3E-14
1000s	Less than or Equal to 3.2E-15
Floor*	Less than or Equal to 3.0E-15

Long term drift rate should be less than or equal to 2.0E-16 per day (Achieved after extended period of unperturbed, continuous operation)

Auto tuning: no external reference required

ENVIRONMENTAL

Temperature sensitivity:	Less than 1.0E-14/degrees C
Magnetic sensitivity:	Less than 3.0E-14/Gauss
Power source sensitivity:	Less than 1.0E-14
Barometric Pressure:	Less than 3e-15/kPa

FREQUENCY CONTROL CAPABILITY

Synthesized frequency resolution: Less than or Equal to 7.0E-17 Frequency control range: Greater than or Equal to 7.0E-10

The synthesizer must maintain continuous phase through a frequency change.

AVAILABLE OUTPUTS

Frequency	Amplitude	# of outputs
5 MHz	13dBm	Greater than or Equal to 3
10 MHz	13dBm	Greater than or Equal to 1
100 MHz	13dBm	Greater than or Equal to 1
Load impedance: 50ohmsΩ		

PHASE NOISE

5 MHz outputs	
Offset from carrier	Single Side-Band Phase Noise in a 1Hz Bandwidth
1 Hz	Less than or Equal to -90dBc
10 Hz	Less than or Equal to -110dBc
100 Hz	Less than or Equal to -130dBc
1 KHz	Less than or Equal to -140dBc
10 KHz	Less than or Equal to -150dBc
100 KHz	Less than or Equal to -155dBc

POWER

Operating voltage: 85 to 264 VAC Frequency range: 47 to 63 Hz

Peak power:

Operating power:

Less than or Equal to 150W

Less than or Equal to 75W

External DC input: 22 to 28 VDC At least 3.1A

Standby battery (built-in): No less than 8 hours operation

RELIABILITY

Mean Time Between Failure (MTBF)

No less than 5 years
Separate information on the MTBF for (1) the physics package (cavity, storage bulb, loss of vacuum, hydrogen disassociator, etc) and (2) all other electronic components shall be supplied.

DOCUMENTATION: The contractor shall provide standard technical and operation and maintenance manuals. All applicable software for effective operation of the system shall also be provided.

WARRANTY: The contractor shall provide a standard commercial warranty against all parts and labor

DELIVERY: System delivery shall be no later than three (3) months after contract award.